



CERTIFICATE OF APPROVAL No CF 119

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products The undermentioned products of

DORMA UK LTD

Wilbury Way, Hitchin, Hertfordshire SG4 0AB Tel: 01462 477600 Fax: 01462 477601

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

CERTIFIED PRODUCT
DORMA TS 90, TS 91, TS 92, TS
93, TS 97 and TS 99 Overhead
Mounted Door Closers

TECHNICAL SCHEDULE
TS 34 - The Contribution Of
Controlled Door Closing
Devices And Accessories To
Fire Resisting Doorsets

Signed and sealed for and on behalf of Exova (UK) Limited trading as Warrington Certification

Sir Ken Knight
Chairman
Impartiality Committee

Paul Duggan
Certification Manager



Issued: Reissued: Valid to: 3rd February 1992 29th June 2017 28th June 2022

Page 1 of 7







DORMA TS 90, TS 91, TS 92, TS 93, TS 97 and TS 99 OVERHEAD MOUNTED DOOR CLOSERS

1. Dorma TS90, TS 91, TS 92, TS 93, TS 97 and TS 99 are overhead mounted cam action door closing devices. The TS 92, TS 93 and TS 99 have adjustable power. The TS 93 also includes integral back check and delayed action. The TS 99 is a free swing unit complying with EN 1155. This approval relates to the following configurations:

		Link-arms			Slide arms			
	Projecting arm (Fig. 1) Body door mounted on pull face	Projecting arm (Fig. 61) Body transom mounted on push face	Parallel arm (Fig. 6) Body door mounted on push face	Body door mounted on pull face	Body transom mounted on push face	Body door mounted on push face	Body transom mounted on pull face	
TS 90	×	×	×	✓	*	×	✓	
TS 91 B	×	×	*	✓	✓	×	×	
TS 92 B	×	×	*	✓	✓	×	×	
TS 92 G	×	×	×	×	×	✓	✓	
TS 93 B 2-5	×	×	×	✓	✓	×	×	
TS 93 G 2-5	×	×	×	×	×	✓	✓	
TS 93 B 5-7	×	×	*	✓	*	×	×	
TS 93 G 5-7	×	×	*	*	*	×	✓	
TS 97	×	×	×	✓	*	*	✓	
TS 99 FL	×	×	*	✓	*	*	✓	
G-EMF	×	×	*	✓	*	✓	*	
G-EMR	×	*	*	✓	*	✓	*	
GSR	×	×	×	✓	×	×	×	
GSR EMF	×	×	×	✓	*	*	×	
GSR EMR	×	*	*	✓	*	*	*	

Key: ✓ - approved

Not approved

Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.

2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), the Technical Handbooks (Scotland) and Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.

Page 2 of 7 Signed AJ/002 & C/014

the ful ligger





DORMA TS 90, TS 91, TS 92, TS 93, TS 97 and TS 99 OVERHEAD MOUNTED DOOR CLOSERS

3. This approval relates to its use with the following door assemblies:-

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (Code ITT).

Latched and unlatched door assemblies (intumescent sealed or non-intumescent sealed) consisting of uninsulated or insulated metal door assemblies in metal frames, having a fire resistance of up to 240 minutes (IMM and MM)*.

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in steel frames having a fire resistance up to 120 minutes (Code ITM)*.

* G-EMF, G-EMR, GSR EMF and GSR EMR accessories are not approved for use with uninsulated steel door assemblies, or ITM door assemblies with uninsulated steel frames.

- 4. The closers are approved on the basis of:
 - Initial type testing to EN1154 and BS EN 1634-1.
 - ii) An appraisal against TS34
 - iii) Inspection of quality management system
 - iv) Inspection and surveillance of factory production control
 - v) Ongoing audit testing in accordance with EN 1154 requirements
- 5. This approval is applicable only to the specified closers used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
- 6. The approval relates to on going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Page 3 of 7 Signed AJ/002 & C/014

the fel ligg-





DORMA TS 90, TS 91, TS 92, TS 93, TS 97 and TS 99 OVERHEAD MOUNTED DOOR CLOSERS

7. The following table shows acceptable doorsets types and fire resistance periods:

	Approved Door Type					
Class	IMM	MM	ITT	ITM	ITC	
FD20	√ *	√ *	✓	√*	×	
FD30	√ *	√*	✓	√ *	×	
FD60	√ *	√*	✓	√*	×	
FD120	√ *	√*	✓	√*	×	
FD240	√ *	√*	×	×	×	
E 20	√ *	√*	✓	√*	×	
EI 20	√ *	√*	✓	√*	×	
E 30	√ *	√*	✓	√ *	×	
EI 30	√ *	√*	✓	√*	×	
E 60	√ *	√*	✓	√ *	×	
EI 60	√ *	√*	✓	√*	×	
E 90	√ *	√*	✓	√ *	×	
EI 90	√ *	√*	✓	√*	×	
E 120	√ *	√*	✓	√ *	*	
EI 120	√ *	√*	✓	√*	*	
E 240	√ *	√*	×	×	*	
EI 240	√*	√*	×	×	×	

Kev:

- ✓ approved
- Not approved
- ✓* G-EMF, G-EMR, GSR EMF and GSR EMR accessories are not approved for use with uninsulated steel door assemblies, or ITM door assemblies with uninsulated steel frames.

Page 4 of 7 Signed AJ/002 & C/014

top fol agg-





DORMA TS 90, TS 91, TS 92, TS 93, TS 97 and TS 99 OVERHEAD MOUNTED DOOR CLOSERS

8. Doors are classified as the following types:

Type IMM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

Type ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

Type ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

Type ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Scope of Approval:

- Doors may not include uninsulated glass above 20% of their total area.
- All closer models are only approved in the fitting applications detailed with their classification codes.
- Mechanical hold open option is not approved.

Classification codes

The approval provides the following classifications:

Dorma TS 90

Door leaf mounted pull side and transom mounted pull side only:

3 8	3	1	1	3
-----	---	---	---	---

Dorma TS 91 B

Door leaf mounted pull side and transom mounted push side only (model suffixed B)

|--|

9.

Page 5 of 7 Signed AJ/002 & C/014

Al Ragge





DORMA TS 90, TS 91, TS 92, TS 93, TS 97 and TS 99 OVERHEAD MOUNTED DOOR CLOSERS

Classification codes (continued)

Dorma TS 92 B & TS 92 G

Door leaf mounted pull side and transom mounted push side (model suffixed B) Door leaf mounted push side and transom mounted pull side (model suffixed G)

4 8	4 3	1	1	3
-----	-----	---	---	---

Dorma TS 93 B & TS 93 G (EN 2-5)

Door leaf mounted pull side and transom mounted push side (model suffixed B) Door leaf mounted push side and transom mounted pull side (model suffixed G)

4 8 5 3	1	1	4
---------	---	---	---

Dorma TS 93 B/G EN 5-7

Door leaf mounted pull side (model suffixed B)

Transom mounted pull side (model suffixed G)

4 8 7 5	1	1	4
---------	---	---	---

Dorma TS 97

Door leaf mounted pull side and transom mounted pull side only

3 8	4 3	1	1	3
-----	--------	---	---	---

Dorma TS 99 FL EN 2-5 (EN1155) – Standard or Top jamb Installation Door leaf mounted pull side and transom mounted pull side only

3	8	5 3	1	1	3
---	---	--------	---	---	---

Page 6 of 7 Signed AJ/002 & C/014

Allen Pal Regg-





DORMA TS 90, TS 91, TS 92, TS 93, TS 97 and TS 99 OVERHEAD MOUNTED DOOR CLOSERS

Accessories

- The following accessories are approved for use with the TS 91, TS 92 and TS 93:
 - o G-EMF Electro-mechanical hold-open
 - o G-EMR Electro-mechanical hold-open and integral smoke detector
 - o GSR Standard door co-ordinator
 - o GSR EMF Door co-ordinator with electro-mechanical hold-open
 - o GSR EMR Door co-ordinator with integral smoke detector

Classification of these slide arm channels is given as follows:

G-EMR & G-EMF

Closer body door leaf mounted pull side and door leaf mounted push side only

3 8	5 3	1	1	3
-----	--------	---	---	---

GSR, GSR-EMR & GSR-EMF

Closer body door leaf mounted pull side only

3 8	5 3	1	1	3
-----	--------	---	---	---

Note 1: Where one of the above slide arm channels are used in conjunction with a closer model having a differing classification code, the lower code shall apply.

Note 2: G-EMF, G-EMR, GSR EMF and GSR EMR accessories are not approved for use with uninsulated steel door assemblies or ITM door assemblies with uninsulated steel frames.

Further Information

Further information regarding the details contained in this data sheet may be obtained from Dorma UK Limited (Tel: 01462 477600).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 7 of 7 Signed AJ/002 & C/014

Al Rage